

SAN DIEGO UNIFIED SCHOOL DISTRICT DRINKING WATER SAMPLING

Site:	Language Academy	Date:	12/13/17	
Sampler:	SDUSD - Safety Office	Analyzed By:	EnviroMatrix Analytical, Inc	
		Federal Action Level (AL) is 15 parts per billion (PPB). District AL is 5 PPB. Green shading = below District & Federal Action Levels Yellow shading = below Federal Action level/Above District Action Level Red Shading = above Federal Action Level ND = Analyte NOT DETECTED at or above the reporting limit		
Sample ID	Sample Location	Lead Results	Units	Type of Fixture
1	100 Bldg, Rm 10 E-Wall	5.78	ug/L	DB
2	100 Bldg, Rm 11 E-Wall	4.40	ug/L	DB
3	100 Bldg, Exterior NE Side - Left Bubblers (Previously Sampled)	5.58	ug/L	DB
4	100 Bldg Exterior NE Side - Right Bubblers Secured		ug/L	DB
5	200 Bldg, Rm 8 E-Wall	5.72	ug/L	DB
6	200 Bldg, Rm 9 E-Wall	4.86	ug/L	DB
7	200 Bldg, Exterior, W-Wall, L-Side Bubblers	2.20	ug/L	DB
8	200 Bldg, Exterior, W-Wall, C-Side Bubblers	0.60	ug/L	DB
9	200 Bldg, Exterior, W-Wall, R-Side Bubblers	0.56	ug/L	DB
10	200 Bldg, Nurse's Office	1.02	ug/L	CF
11	200 Bldg, Faculty Work Rm	3.43	ug/L	CF
12	200 Bldg, Faculty Work Rm	2.79	ug/L	DB
13	Kitchen, West Wall	1.68	ug/L	KF
14	Kitchen/Cafeteria Bldg, Teacher's Dining Rm SW-Side of Bldg	9.78	ug/L	CF
15	400 Bldg, Exterior N-Wall, L-Side Bubblers	2.75	ug/L	DB
16	400 Bldg, Exterior N-Wall, C-Side Bubblers (Previously Sampled)	< 5	ug/L	DB
17	400 Bldg, Exterior N-Wall, R-Side Bubblers	1.22	ug/L	DB
18	400 Bldg, Rm 3, NE Wall	6.77	ug/L	DB
19	400 Bldg, Rm 4, NE Wall Secured (Previously Sampled)	6.61	ug/L	DB
20	400 Bldg, Rm 5, NE Wall	4.28	ug/L	DB
21	400 Bldg, Rm 6, NE Wall	6.24	ug/L	DB
22	400 Bldg, Rm 7, NE Wall	5.47	ug/L	DB
23	400 Bldg, Exterior SW-Wall, L-Side Bubblers (Previously Sampled)	< 5	ug/L	DB
24	400 Bldg, Exterior SW-Wall, R-Side Bubblers	0.89	ug/L	DB
25	Rm 1 NW Wall	1.70	ug/L	DB

Coding: DB=Drinking Water Bubblers; WC=Water Cooler; CF= Classroom Faucet; KF=Kitchen Faucet; NS=Nurse Faucet

SAN DIEGO UNIFIED SCHOOL DISTRICT DRINKING WATER SAMPLING

Site:	Language Academy	Date:	12/13/17	
Sampler:	SDUSD - Safety Office	Analyzed By:	EnviroMatrix Analytical, Inc	
Sample ID	Sample Location	Lead Results	Units	Type of Fixture
Federal Action Level (AL) is 15 parts per billion (PPB). District AL is 5 PPB. Green shading = below District & Federal Action Levels Yellow shading = below Federal Action level/Above District Action Level Red Shading = above Federal Action Level ND = Analyte NOT DETECTED at or above the reporting limit				
26	Rm 2 NW Wall (Previously Sampled)	6.13	ug/L	DB
27	CONTAINER EXTERIOR L (LOWER DOUBLE FOUNTAIN) NW (LOW FLOW), West of B-1	ND	ug/L	DB
28	CONTAINER EXTERIOR R (UPPER DOUBLE FOUNTAIN) NW (LOW FLOW), West of B-1	ND	ug/L	DB
29	B1 NW WALL	0.20	ug/L	DB
30	B2 NW WALL	ND	ug/L	DB
31	B3 NW WALL	ND	ug/L	DB
32	B4 NW WALL	ND	ug/L	DB
33	B5 NW WALL	ND	ug/L	DB
34	B6 NW WALL	ND	ug/L	DB
35	B7 NW WALL	ND	ug/L	DB
36	STAFF LOUNGE SW WALL	0.48	ug/L	CF
37	LIBRARY-WORK ROOM W WALL	0.54	ug/L	CF
38	700 Bldg, Rm 704D, North Wall	0.26	ug/L	DB
39	700 Bldg, Rm703C, North Wall	0.26	ug/L	DB
40	700 Bldg, Exterior Bubbler, East facing Wall, L-side	0.32	ug/L	DB
41	700 Bldg, Exterior Bubbler, East facing Wall, R-side	0.33	ug/L	DB
42	700 Bldg, Rm 705	0.32	ug/L	CF
43	700 Bldg, Rm 706, Southwest Wall	0.27	ug/L	DB
44	700 Bldg, Rm 707, Southwest Wall	0.18	ug/L	DB
45	700 Bldg, 2nd Flr, Northwest Exterior Wall L-side		ug/L	DB
46	700 Bldg, 2nd Flr, Northwest Exterior Wall R-side	0.16	ug/L	DB
47	700 Bldg, Rm 708, West Wall	0.22	ug/L	DB

Coding: DB=Drinking Water Bubbler; WC=Water Cooler; CF= Classroom Faucet; KF=Kitchen Faucet; NS=Nurse Faucet

SAN DIEGO UNIFIED SCHOOL DISTRICT DRINKING WATER SAMPLING

Site:	Language Academy	Date:	12/13/17	
Sampler:	SDUSD - Safety Office	Analyzed By:	EnviroMatrix Analytical, Inc	
		Federal Action Level (AL) is 15 parts per billion (PPB). District AL is 5 PPB. Green shading = below District & Federal Action Levels Yellow shading = below Federal Action level/Above District Action Level Red Shading = above Federal Action Level ND = Analyte NOT DETECTED at or above the reporting limit		
Sample ID	Sample Location	Lead Results	Units	Type of Fixture
48	700 Bldg, Rm 709, West Wall	ND	ug/L	DB
49	800 Bldg, Exterior Bubbler at Elevator/ East Wall-Left	ND	ug/L	DB
50	800 Bldg, Exterior Bubbler at Elevator/ East Wall-Right	ND	ug/L	DB
51	800 Bldg, Rm 801	ND	ug/L	CF
52	800 Bldg, Rm 802- South Wall	ND	ug/L	DB
53	800 Bldg, Rm 803- North Wall	ND	ug/L	DB
54	800 Bldg, Rm 804- West Wall	ND	ug/L	DB
55	800 Bldg, Rm 805 -East Wall	ND	ug/L	DB
56	800 Bldg, Rm 806-West Wall	ND	ug/L	DB
57	800 Bldg, Rm 807- East Wall	ND	ug/L	DB
58	800 Bldg, 2nd Floor, Rm 808- North Wall-	ND	ug/L	CF
59	800 Bldg, Exterior at Elevator, 2nd Floor, East Wall-Left	ND	ug/L	CF
60	800 Bldg, Exterior at Elevator, 2nd Floor, East Wall- Right	ND	ug/L	DB
61	800 Bldg, 2nd Floor, Rm 809-West Wall	ND	ug/L	DB
62	800, Bldg, 2nd Floor, Rm 810- West Wall	ND	ug/L	CF
63	800 Bldg, 2nd Floor, Rm 811-North Wall	ND	ug/L	CF
64	800 Bldg, 2nd Floor, Rm 812-North Wall	ND	ug/L	CF
65	800 Bldg, 2nd Floor, Rm 813- North Wall	ND	ug/L	CF
66	800 Bldg, 2nd Floor, Rm 814- North Wall	ND	ug/L	CF

Coding: DB=Drinking Water Bubbler; WC=Water Cooler; CF= Classroom Faucet; KF=Kitchen Faucet; NS=Nurse Faucet

SAN DIEGO UNIFIED SCHOOL DISTRICT DRINKING WATER SAMPLING


Coding: DB=Drinking Water Bubbler; WC=Water Cooler; CF= Classroom Faucet; KF=Kitchen Faucet; NS=Nurse Faucet

SAN DIEGO UNIFIED SCHOOL DISTRICT DRINKING WATER SAMPLING



Coding: DB=Drinking Water Bubbler; WC=Water Cooler; CF= Classroom Faucet; KF=Kitchen Faucet; NS=Nurse Faucet

SAN DIEGO UNIFIED SCHOOL DISTRICT DRINKING WATER SAMPLING



Coding: DB=Drinking Water bubbler; WC=Water Cooler; CF= Classroom Faucet; KF=Kitchen Faucet; NS=Nurse Faucet