

# SAN DIEGO UNIFIED SCHOOL DISTRICT DRINKING WATER SAMPLING

Site: Montezuma Childhood Development Center

3-Aug-17

Sampler SDUSD-Safety Office

Enviromatrix Labs: 17F0886 Montezuma CDC

Sample ID	Date	Description	Lead	Units	Type of Fixture
1	28-Jun	Main Office lunch room	10	ug/l	drinking fountain
2	28-Jun	Room 1	53	ug/l	single left wall drinking fountain
3	28-Jun	Room 2	ND	ug/l	drinking fountain
4	28-Jun	Restroom near room 3	ND	ug/l	rightside drinking fountain
5	28-Jun	Room 3	5	ug/l	drinking fountain