

SAN DIEGO UNIFIED SCHOOL DISTRICT DRINKING WATER SAMPLING

Site: Revere Center

7-Aug-17

Sampler SDUSD-Safety Office

analyzed by: Enviromatrix Labs17G0820 Revere Center

Sample ID	Sample Date	Sample Location	Lead result	Units	Type of Fixture
1	27-Jul	Room 3 - Work Permit Applications	ND	ug/l	sink faucet
2	27-Jul	Room 5 – Food Services, Sink in the Director’s Office	ND	ug/l	sink faucet
3	27-Jul	Room 5 – Food Services, wall-mounted in the hallway	29	ug/l	water cooler
4	27-Jul	Room 5 – Food Services, 3-compartment sink in the Kitchen	6	ug/l	sink faucet
5	27-Jul	Room 7 – Risk Management	ND	ug/l	sink faucet