

SAN DIEGO UNIFIED SCHOOL DISTRICT DRINKING WATER SAMPLING

Site:	Bird Rock Elementary School	Date:	04/10/18	
Sampler:	SDUSD - Safety Office	Analyzed By:	EnviroMatrix Analytical, Inc	
<p>Federal Action Level (AL) is 15 parts per billion (PPB). District AL is 5 PPB. Green shading = below District & Federal Action Levels Yellow shading = below Federal Action level/Above District Action Level Red Shading = above Federal Action Level</p>				
Sample ID	Sample Location	Lead Results	Units	Type of Fixture
1	K-2 W-Wall, L-Sink Pipe Disconnected -SD 1	10.5	ug/L	DB
2	K-1 East wall-single fountain	1.9	ug/L	DB
3	K-3 Bungalow-North sink - SD 2	< 5	ug/L	DB
4	K-4 Bungalow-North sink	1.0	ug/L	DB
5	Admin Bldg, Nurse's Area, E-Wall	6.1	ug/L	NF
6	Admin Bldg, Workroom, N-Wall	8.5	ug/L	KF
7	Auditorium/ East Ext Wall at Mens RR-Right Bubbler	2.3	ug/L	DB
8	Auditorium, Ext E-Wall at Mens RR, L-Bubbler -SD 3	< 5	ug/L	DB
9	Auditorium, Resource Rm (Prime Time/PTA), S-wall Faucet	2.6	ug/L	KF
10	Kitchen- East Wall/ 2 sink- Swing Arm - SD 4	< 5	ug/L	KF
11	Kitchen-South Wall/ 3 sink- Swing Arm	1.2	ug/L	KF
12	RM B1 S WALL	.92	ug/L	DB
13	RM B2 S WALL	.62	ug/L	DB
14	RM B3 S WALL	.89	ug/L	DB
15	RM B4 S WALL	1.4	ug/L	DB
16	RM B5 S WALL	1.3	ug/L	DB
17	LIBRARY WORKROOM 504 S WALL	1.4	ug/L	CF
18	B6, NW Wall	1.0	ug/L	DB
19	B7, NW Wall	.84	ug/L	DB
20	B8, SE Wall	.83	ug/L	DB
21	B9, SE Wall	.76	ug/L	DB
22	100 Bldg, 2-Story Bldg, Exterior S-Wall, L-Bubbler	1.7	ug/L	DB
23	100 Bldg, 2-Story Bldg, Exterior S-Wall, C-Bubbler - SD 5	< 5	ug/L	DB
24	100 Bldg, 2-Story Bldg, Exterior S-Wall, R-Bubbler	1.6	ug/L	DB
25	100 Bldg, Room 2, Northwest wall	16.0	ug/L	DB

Coding: DB=Drinking Water Bubbler; WC=Water Cooler; CF= Classroom Faucet; KF=Kitchen Faucet; NS=Nurse Faucet

SAN DIEGO UNIFIED SCHOOL DISTRICT DRINKING WATER SAMPLING



Coding: DB=Drinking Water Bubbler; WC=Water Cooler; CF= Classroom Faucet; KF=Kitchen Faucet; NS=Nurse Faucet

tt04/10/18