

# SAN DIEGO UNIFIED SCHOOL DISTRICT DRINKING WATER SAMPLING

Site:	Mann Middle School	Report Date:	05/01/18
Sampler:	SDUSD - Safety Office		
<p><b>Federal Action Level (AL) is 15 parts per billion (PPB). District AL is 5 PPB.</b></p> <p>Green shading = below District &amp; Federal Action Levels</p> <p>Yellow shading = below Federal Action level/Above District Action Level</p> <p>Red Shading = above Federal Action Level</p> <p>Units = ug/L</p>			
Sample ID	Sample Location	Lead Results	Type of Fixture
1	Admin Bldg, Work Rm next to Conf Rm, NW Side	13	KF
2	Admin Bldg, Interior Hallway, SW Side, Single Bubbler	5.8	DB
3	Admin Bldg, Nurse's Office, E-Wall	9.0	NS
4	Ext Admin Bldg, E-Wall, Far Left Bubbler SD 1	< 5	DB
5	Ext Admin Bldg, E-Wall, 2nd from Left Bubbler	4.1	DB
6	Ext Admin Bldg, E-Wall, 2nd from Right Bubbler	2.0	DB
7	<b>Ext Admin Bldg, E-Wall, Far Right Bubbler (turned off)</b>		DB
8	Auditorium Bldg, Interior S-Hallway, N-Wall, Single Bubbler	1.5	DB
9	Auditorium Bldg, Interior W-Hallway E-Wall, Single Bubbler	1.8	DB
10	Rm 301, West Wall, low flow (not working) DWO - 047	10.2	DB
11	300 Bldg, Hallway, S-Wall, W-Side, Single Bubbler SD 3	9.31	DB
12	300 Bldg, Hallway, S-Wall, E-Side, Single Bubbler	7.2	DB
13	300 Bldg, Ext Cafeteria, South Wall, Left Bubbler (Very low flow)	17.0	DB
14	300 Bldg, Ext Cafeteria, South Wall, Center Bubbler (Very low flow)	7.8	DB
15	300 Bldg, Ext Cafeteria, North Wall, Right Bubbler (Very low flow)	5.7	DB
16	<b>300 Bldg, Ext Cafeteria, E-Wall, L-Side (Secured)</b>		DB
17	300 Bldg, Ext Cafeteria, E-Wall, Center (Removed) SD 2	6.98	
18	<b>300 Bldg, Ext Cafeteria, E-Wall, R-Side (Secured)</b>		DB
19	300 Bldg, Interior, Cafeteria, S-Wall, Left Bubbler (Very low flow)		DB
20	300 Bldg, Interior Cafeteria, S-Wall, Right Bubbler (Very low flow)		DB
21	300 Bldg, Kitchen, North Wall, Snack Bar Cash Register Area	5.8	KF
22	Interior, Kitchen, 2-Compartment Sink SD 4	< 5	KF
23	Interior, Salad Kitchen, South Wall	1.3	DB
24	400 Bldg Hallway - west wall next to Transformer rm single station	0.74	DB
25	410 - West wall at sink-Left DB Turned Off DWO - 032	21.8	DB
26	410- West wall at sink-Right DWO - 52	8.2	DB

Coding: DB=Drinking Water Bubbler; WC=Water Cooler; CF= Classroom Faucet; KF=Kitchen Faucet; NS=Nurse Faucet  
 ND = Non Detectable; SD1 - SD 5 = Sampled by City of San Diego

# SAN DIEGO UNIFIED SCHOOL DISTRICT DRINKING WATER SAMPLING

Site:	Mann Middle School	Report Date:	05/01/18
Sampler:	SDUSD - Safety Office		
<b>Federal Action Level (AL) is 15 parts per billion (PPB). District AL is 5 PPB.</b> Green shading = below District & Federal Action Levels Yellow shading = below Federal Action level/Above District Action Level Red Shading = above Federal Action Level Units = ug/L			
Sample ID	Sample Location	Lead Results	Type of Fixture
27	409- East wall at sink	2.0	DB
28	600 LOWER N EXTERIOR TRIPLE FOUNTAIN, L-Bubbler	0.81	DB
29	600 LOWER N EXT TRIPLE, C-Bubbler SD 5	< 5	DB
30	600 LOWER N EXTERIOR TRIPLE FOUNTAIN, R-Bubbler	0.48	DB
31	600 RM 651-STORAGE ROOM N WALL (Not Accessible)	9.7	CF
32	600 RM 653-STORAGE ROOM W WALL	31.0	CF
33	600 UPPER N HALLWAY, E WALL TRIPLE FOUNTAIN, L-Bubbler	4.3	DB
34	600 UPPER N HALLWAY, E WALL TRIPLE FOUNTAIN, Center Bubbler	2.8	DB
35	600 UPPER N HALLWAY, E WALL TRIPLE FOUNTAIN, R-Bubbler	1.4	DB
36	600 LOWER S HALLWAY, E WALL TRIPLE FOUNTAIN, L-Bubbler	1.4	DB
37	600 LOWER S HALLWAY, E WALL TRIPLE FOUNTAIN, R- Bubbler	2.8	DB
38	LINGLE GYM, N WALL Cuspidor	1.9	DB
39	BOYS LOCKER ROOM, E WALL	4.6	DB
40	BOYS LOCKER ROOM S EXTERIOR DOUBLE FOUNTAIN, L- Bubbler	3.9	DB
41	BOYS LOCKER ROOM S EXTERIOR DOUBLE FOUNTAIN, R- Bubbler	6.0	DB
42	200 Bldg, library workroom	9.7	CF
43	200 Bldg, Hallway, across from 201 North wall bubbler	5.8	DB
44	200 Bldg, Room 205, East Wall, Right side	8.4	CF
45	200 Bldg, Room 208 East Wall Far Left	20	CF
46	200 Bldg, Room 208, East Wall, Far Right	11	CF
47	200 Bldg, Room 208 Island	13	CF
48	200 Bldg, Rm 207, Teacher Lounge, Kitchenette, South Wall	15	CF
49	200 Bldg, Room 206, South Wall Bubbler	2.8	DB
50	Girls PE Lockerroom-Interior, W-Wall at Lockers	5	DB
51	Girls PE Exercise room-Interior, SE-Side	16	DB
52	Room 305 DWO 53	ND	DB

Coding: DB=Drinking Water Bubbler; WC=Water Cooler; CF= Classroom Faucet; KF=Kitchen Faucet; NS=Nurse Faucet  
 ND = Non Detectable; SD1 - SD 5 = Sampled by City of San Diego

