

SAN DIEGO UNIFIED SCHOOL DISTRICT DRINKING WATER SAMPLING

Site: Cabrillo Elementary School Date: 05/04/2018

Sampler: SDUSD - Safety Office

Federal Action Level (AL) is 15 parts per billion (PPB). District AL is 5 PPB.
 Green shading = below District & Federal Action Levels
 Yellow shading = below Federal Action level/Above District Action Level
 Red Shading = above Federal Action Level
 Units = ug/L

Sample ID	Sample Location	TMA/DWO #	Lead Results	Clearance Date	Clearance Result	Type of Fixture
1	Office, Nurse Office, South Wall	DWO-041-001	4.92			DB
2	K-1, Ext. West Wall, Bubbler SD 1	DWO-041-002	< 5			DB
3	K-1, North Wall, Bubbler on right side	DWO-041-003	8.82			DB
4	K-2, South Wall, Left Bubbler	DWO-041-004	5.14			DB
5	K-2, South Wall, Right Bubbler	DWO-041-005	5.55			DB
6	B-6, West Wall Bubbler SD 5	DWO-041-006	< 5			DB
7	BLDG RMS B1-B2 EXTERIOR S WALL Left Bubbler (Low Flow)	DWO-041-007	14.91			DB
8	BLDG RMS B1-B2 EXTERIOR S WALL Center Bubbler	DWO-041-008	6.51			DB
9	BLDG RMS B1-B2 EXTERIOR S WALL Right Bubbler	DWO-041-009	7.29			DB
10	RM B2 S WALL	DWO-041-010	9.8			DB
11	RM B1 S WALL	DWO-041-011	6.68			DB
12	Auditorium Hallway, E-Wall, Left Bubbler - Secured by Site	DWO-041-012				DB
13	Auditorium Hallway, E-Wall, Right Bubbler - Secured by Site	DWO-041-013				DB
14	Staff Lounge near cafeteria, S-wall	DWO-041-014	15.35			DB
15	Kitchen, W-Wall	DWO-041-015	4.26			DB
16	Rm. # 14 W wall at sink single fountain	DWO-041-016	6.43			CF
17	Rm. # 12 E wall at sink single fountain	DWO-041-017	6.87			DB
18	Rm.# 11 W wall at sink single fountain	DWO-041-018	4.51			DB
19	Rm. # 10 E wall at sink single fountain	DWO-041-019	6.73			DB
20	Outside N near boys RR Left fountain	DWO-041-020	31.4			DB
21	Outside N near boys RR Right fountain SD 3	DWO-041-021	ND			DB
22	Rm 15-Interior-North Wall SD 4	DWO-041-022	8.69			DB
23	Rm 16-Interior- South Wall	DWO-041-023	15.32			DB
24	Rm 17- Interior-North Wall - valve secured by teacher	DWO-041-024				DB
25	Rm 18-Interior-South Wall	DWO-041-025	12.74			DB

Coding: DB=Drinking Water Bubbler; WC=Water Cooler; CF= Classroom Faucet; KF=Kitchen Faucet; NS=Nurse Faucet; ND=Non Detectable

SD 1 - SD 5 = Sampled by City of San Diego

SAN DIEGO UNIFIED SCHOOL DISTRICT DRINKING WATER SAMPLING

Coding: DB=Drinking Water Bubbler; WC=Water Cooler; CF= Classroom Faucet; KF=Kitchen Faucet; NS=Nurse Faucet; ND=Non Detectable
SD 1 - SD 5 = Sampled by City of San Diego