

October 09, 2018

Andrea Frost
Principal
Bird Rock Elementary
5371 La Jolla Hermosa Avenue
San Diego, CA 92037

Subject: Bird Rock Elementary Drinking Water Project Closeout

Dear Andrea Frost:

The following information is provided as a project closeout report for the recent drinking water lead remediation work at the Bird Rock Elementary campus.

As part of a district wide effort the Safety Office began testing all drinking water outlets at Bird Rock Elementary for elevated levels of lead. Safety Office staff first identified all drinking water outlets and tagged them with a blue sticker. Safety Office staff then collected water samples from each drinking water outlet and delivered the samples to an accredited local laboratory for analysis. The federal EPA standard for lead in drinking water is 15 parts per billion (ppb); however, the district standard is much more stringent at 5 ppb. Drinking water fixtures that measured above the district standard were tagged "out of service" while remedial actions took place.

The attached report shows that some drinking water fixtures required remedial action in order to meet the district's strict standard of 5 ppb. Once the remedial action was completed, a re-test was conducted to confirm the remedial action was successful. All site repairs are now complete, please see the attached sampling log for more information. This project is considered closed.

Now that all drinking water outlets on the Bird Rock Elementary campus meet the district's lead standard of 5 ppb, your campus is now cleared from the district's daily water flushing requirement. Instead, please instruct staff to flush all drinking water outlets marked with a blue sticker for one minute in the morning of the first day of school each week, rather than every morning. Please let me know if you have any questions.

Sincerely,

Steven J. Ditto
Manager, Facilities Planning



SAN DIEGO UNIFIED SCHOOL DISTRICT DRINKING WATER SAMPLING REPORT

Facility: Bird Rock Elementary

Report Type: Close Out Report

Date of Report: 10/1/2018

Location	DWO No	Type	Initial Result*	Action Taken**	Clearance Result
1 2 Admin - Bird Rock_01-02 Nurse First Aid	DWO-029-001	Faucet	6.10	FLTR	ND
2 2 Admin - Bird Rock_01-02 MDF	DWO-029-002	Faucet	8.50	FLTR	ND
3 4 Kinder Rms K01-K02 - Bird Rock_01-04 Classroom - K02	DWO-029-003	Drinking Fountain Bubblers	10.50	FLTR	ND
4 4 Kinder Rms K01-K02 - Bird Rock_01-04 Classroom - K01	DWO-029-004	Drinking Fountain Bubblers	1.90	INIT	
5 Portable K03 - Bird Rock Classroom - K03	DWO-029-005	Drinking Fountain Bubblers	<5	INIT	
6 Portable K04 - Bird Rock Classroom - K04	DWO-029-006	Drinking Fountain Bubblers	1.00	INIT	
7 1 Classrooms 1-10/Supply - Bird Rock_01-01 Classroom - 02	DWO-029-007	Drinking Fountain Bubblers	16.00	FLTR	ND
8 1 Classrooms 1-10/Supply - Bird Rock_01-01 Classroom - 01	DWO-029-008	Drinking Fountain Bubblers	2.20	INIT	
9 1 Classrooms 1-10/Supply - Bird Rock_01-01 Classroom - 04	DWO-029-009	Drinking Fountain Bubblers	1.80	INIT	
10 1 Classrooms 1-10/Supply - Bird Rock_01-01 Classroom - 03	DWO-029-010	Drinking Fountain Bubblers	2.10	INIT	
11 1 Classrooms 1-10/Supply - Bird Rock_01-01 Classroom - 06	DWO-029-011	Drinking Fountain Bubblers	2.70	INIT	
12 1 Classrooms 1-10/Supply - Bird Rock_01-01 Classroom - 05	DWO-029-012	Drinking Fountain Bubblers	4.70	INIT	
13 1 Classrooms 1-10/Supply - Bird Rock_01-01 Classroom - 08	DWO-029-013	Drinking Fountain Bubblers	1.70	INIT	
14 1 Classrooms 1-10/Supply - Bird Rock_01-01 Classroom - 07	DWO-029-014	Drinking Fountain Bubblers	0.75	INIT	
15 1 Classrooms 1-10/Supply - Bird Rock_01-01 Classroom - 10	DWO-029-015	Drinking Fountain Bubblers	3.70	INIT	
16 1 Classrooms 1-10/Supply - Bird Rock_01-01 Hallway	DWO-029-016	Drinking Fountain Bubblers	2.60	INIT	
17 1 Classrooms 1-10/Supply - Bird Rock_01-01 Hallway	DWO-029-017	Drinking Fountain Bubblers	1.80	INIT	



SAN DIEGO UNIFIED SCHOOL DISTRICT DRINKING WATER SAMPLING REPORT

Facility: Bird Rock Elementary

Report Type: Close Out Report

Date of Report: 10/1/2018

	Location	DWO No	Type	Initial Result*	Action Taken**	Clearance Result
18	1 Classrooms 1-10/Supply - Bird Rock_01-01 Building Exterior	DWO-029-018	Drinking Fountain Bubblers	1.70	INIT	
19	1 Classrooms 1-10/Supply - Bird Rock_01-01 Building Exterior	DWO-029-019	Drinking Fountain Bubblers	<5	INIT	
20	1 Classrooms 1-10/Supply - Bird Rock_01-01 Building Exterior	DWO-029-020	Drinking Fountain Bubblers	1.60	INIT	
21	Portable B06 - Bird Rock Classroom - B06	DWO-029-021	Drinking Fountain Bubblers	1.00	INIT	
22	Portable B08 - Bird Rock Classroom - B08	DWO-029-022	Drinking Fountain Bubblers	0.83	INIT	
23	Portable B07 - Bird Rock Classroom - B07	DWO-029-023	Drinking Fountain Bubblers	0.84	INIT	
24	Portable B09 - Bird Rock Classroom - B09	DWO-029-024	Drinking Fountain Bubblers	0.76	INIT	
25	5 Library - Bird Rock_02-05 Workroom	DWO-029-025	Faucet	1.40	INIT	
26	Portable B05 - Bird Rock Classroom - B05	DWO-029-026	Drinking Fountain Bubblers	1.30	INIT	
27	Portable B04 - Bird Rock Classroom - B04	DWO-029-027	Drinking Fountain Bubblers	1.40	INIT	
28	Portable B03 - Bird Rock Classroom - B03	DWO-029-028	Drinking Fountain Bubblers	0.89	INIT	
29	Portable B02 - Bird Rock Classroom - B02	DWO-029-029	Drinking Fountain Bubblers	0.62	INIT	
30	Portable B01 - Bird Rock Classroom - B01	DWO-029-030	Drinking Fountain Bubblers	0.92	INIT	
31	3 Auditorium/Cafeteria/Kitchen - Bird Rock_01-03 Kitchen	DWO-029-031	Faucet	<5	INIT	
32	3 Auditorium/Cafeteria/Kitchen - Bird Rock_01-03 Kitchen	DWO-029-032	Faucet	1.20	INIT	
33	3 Auditorium/Cafeteria/Kitchen - Bird Rock_01-03 Resource Study Rm	DWO-029-033	Faucet	2.60	INIT	
34	3 Auditorium/Cafeteria/Kitchen - Bird Rock_01-03 Building Exterior	DWO-029-034	Drinking Fountain Bubblers	<5	INIT	



SAN DIEGO UNIFIED SCHOOL DISTRICT DRINKING WATER SAMPLING REPORT

Facility: Bird Rock Elementary

Report Type: Close Out Report

Date of Report: 10/1/2018

Location	DWO No	Type	Initial Result*	Action Taken**	Clearance Result
35 3 Auditorium/Cafeteria/Kitchen - Bird Rock_01-03 Building Exterior	DWO-029-035	Drinking Fountain Bubbler	2.30	INIT	

*Action levels and color indication

Federal action level is above 15ppb (parts per billion). SDUSD uses an action level that is stricter and includes anything above 5 PPB. Items indicated in green are below District action level. Items indicated in yellow are above District action level. Items indicated in red are above both District and Federal action levels. Green indicates no action needed. Red/Yellow indicates action needed.

**Clearance actions

INIT=Initial result cleared no action needed. FLTR=Filter has been installed. PLMB=Plumbing work performed. RRC=Repeat and repeat-confirmation testing has been performed and both samples yielded results below District action level. RMOV=The drinking water outlet has been removed from service.