

October 23, 2018

Chuck Podhorsky
Principal
La Jolla High
750 Nautilus St.
San Diego, CA 92037

Subject: La Jolla High School Drinking Water Project Closeout

Dear Chuck Podhorsky:

The following information is provided as a project closeout report for the recent drinking water lead remediation work at the La Jolla High School campus.

As part of a district wide effort the Physical Plant Operations (PPO) staff began testing all drinking water outlets at La Jolla High School for elevated levels of lead. PPO staff first identified all drinking water outlets and tagged them with a blue label. Safety Office staff then collected water samples from each drinking water outlet and delivered the samples to a state certified laboratory for analysis. The federal EPA standard for lead in drinking water is 15 parts per billion (ppb); however, the district standard is much more stringent at 5 ppb. Drinking water fixtures that measured above the district standard were tagged "out of service" while remedial actions took place.

The attached report shows that some drinking water fixtures required remedial action in order to meet the district's strict standard of 5 ppb. Once the remedial action was completed, a re-test was conducted to confirm the remedial action was successful. All site repairs are now complete, please see the attached sampling log for more information. This project is considered closed.

Now that all drinking water outlets on the La Jolla High School campus meet the district's lead standard of 5 ppb, your campus is now cleared from the district's daily water flushing requirement. Instead, please instruct staff to flush all drinking water outlets marked with a blue sticker for one minute in the morning of the first day of school each week, rather than every morning. Please let me know if you have any questions.

Sincerely,

Steven J. Ditto
Manager, Facilities Planning



SAN DIEGO UNIFIED SCHOOL DISTRICT DRINKING WATER SAMPLING REPORT

Facility: La Jolla High School

Report Type: Close Out Report

Date of Report: 10/23/2018

	Location	DWO No	Type	Initial Result*	Action Taken**	Clearance Result
1	100 Admin/Supply - La Jolla High_14-18 Lounge, South Wall	DWO-342-001	Faucet	1.90	INIT	
2	100 Admin/Supply - La Jolla High_14-18 Corridor by Supply Rm, West Wall Left Side	DWO-342-002	Drinking Fountain Bubblers	2.50	INIT	
3	100 Admin/Supply - La Jolla High_14-18 Corridor by Supply Rm, West Wall Right Side	DWO-342-003	Drinking Fountain Bubblers	2.70	INIT	
4	100 Admin/Supply - La Jolla High_14-18 Nurse First Aid, East Wall	DWO-342-004	Faucet	5.00	INIT	
5	100 Admin/Supply - La Jolla High_14-18 Building Exterior, East Wall Left Side	DWO-342-005	Drinking Fountain Bubblers	4.30	INIT	
6	100 Admin/Supply - La Jolla High_14-18 Building Exterior, East Wall Right Side	DWO-342-006	Drinking Fountain Bubblers	2.10	INIT	
7	200 Library Media Center - La Jolla High_14-19 Workroom, West Wall	DWO-342-007	Faucet	2.80	INIT	
8	200 Library Media Center - La Jolla High_14-19 Building Exterior, Courtyard	DWO-342-008	Drinking Fountain Bubblers	5.50	RMOV	NA
9	200 Library Media Center - La Jolla High_14-19 Storage 1st Floor, East Wall	DWO-342-009	Faucet	1.10	INIT	
10	200 Library Media Center - La Jolla High_14-19 Media Production, West Wall	DWO-342-010	Faucet	2.60	INIT	
11	200 Library Media Center - La Jolla High_14-19 Building Exterior, East Wall Left Side	DWO-342-011	Drinking Fountain Bubblers	1.70	INIT	
12	200 Library Media Center - La Jolla High_14-19 Building Exterior, East Wall Right Side	DWO-342-012	Drinking Fountain Bubblers	<5	INIT	
13	300 Classrooms - La Jolla High Classroom - 312, North Wall	DWO-342-013	Faucet	7.00	FLTR	ND
14	300 Classrooms - La Jolla High Building Exterior, Between Boys/Girls RR Left Side	DWO-342-014	Drinking Fountain Bubblers	0.63	INIT	
15	300 Classrooms - La Jolla High Building Exterior, Between Boys/Girls RR Right Side	DWO-342-015	Drinking Fountain Bubblers	<5	INIT	
16	300 Classrooms - La Jolla High Classroom - 304, East Wall	DWO-342-016	Faucet	5.50	FLTR	4.17
17	300 Classrooms - La Jolla High Classroom - 306, East Wall	DWO-342-017	Faucet	4.40	INIT	



SAN DIEGO UNIFIED SCHOOL DISTRICT DRINKING WATER SAMPLING REPORT

Facility: La Jolla High School

Report Type: Close Out Report

Date of Report: 10/23/2018

	Location	DWO No	Type	Initial Result*	Action Taken**	Clearance Result
18	300 Classrooms - La Jolla High Classroom - 305, East Wall	DWO-342-018	Faucet	6.70	FLTR	ND
19	300 Classrooms - La Jolla High Building Exterior, Outside Rm Entrance	DWO-342-019	Drinking Fountain Bubblers	5.00	INIT	
20	300 Classrooms - La Jolla High Classroom - 301, East Wall	DWO-342-020	Faucet	2.70	INIT	
21	300 Classrooms - La Jolla High Classroom - 301, East Side of Building Left Side	DWO-342-021	Drinking Fountain Bubblers	1.40	INIT	
22	300 Classrooms - La Jolla High Building Exterior, East Side of Building Right Side	DWO-342-022	Drinking Fountain Bubblers	1.90	INIT	
23	400 Auditorium - La Jolla High Lobby, South Wall	DWO-342-023	Drinking Fountain Bubblers	4.30	INIT	
24	400 Auditorium - La Jolla High Lobby, South Wall	DWO-342-024	Drinking Fountain Bubblers	1.70	INIT	
25	400 Auditorium - La Jolla High Concession, South Wall	DWO-342-025	Faucet	12.00	FLTR	ND
26	400 Auditorium - La Jolla High Platform, Near Entrance to Dressing Rooms from Stage	DWO-342-026	Drinking Fountain Bubblers	1.60	INIT	
27	500 Classrooms/Cafeteria/Kitchen - La Jolla High_13-17 Dining Rm Students, South Wall Left Side	DWO-342-027	Drinking Fountain Bubblers	8.60	FLTR	ND
28	500 Classrooms/Cafeteria/Kitchen - La Jolla High_13-17 Dining Rm Students, South Wall Right Side	DWO-342-028	Drinking Fountain Bubblers	15.00	FLTR	ND
29	500 Classrooms/Cafeteria/Kitchen - La Jolla High_13-17 Kitchen, South Wall	DWO-342-029	Faucet	1.80	INIT	
30	500 Classrooms/Cafeteria/Kitchen - La Jolla High_13-17 Kitchen, North Wall	DWO-342-030	Faucet	6.34	FLTR	ND
31	500 Classrooms/Cafeteria/Kitchen - La Jolla High_13-17 Kitchen, North Wall	DWO-342-031	Faucet	8.10	FLTR	4.84
32	500 Classrooms/Cafeteria/Kitchen - La Jolla High_13-17 Dining Rm Faculty, South Wall	DWO-342-032	Faucet	12.00	FLTR	ND
33	500 Classrooms/Cafeteria/Kitchen - La Jolla High_13-17 Building Exterior, Northwest Corner Of Cafeteria Area Left	DWO-342-033	Drinking Fountain Bubblers	10.50	FLTR	4.94
34	500 Classrooms/Cafeteria/Kitchen - La Jolla High_13-17 Building Exterior, Northwest Corner Of Cafeteria Area right	DWO-342-034	Drinking Fountain Bubblers	11.00	FLTR	ND



SAN DIEGO UNIFIED SCHOOL DISTRICT DRINKING WATER SAMPLING REPORT

Facility: La Jolla High School

Report Type: Close Out Report

Date of Report: 10/23/2018

	Location	DWO No	Type	Initial Result*	Action Taken**	Clearance Result
35	500 Classrooms/Cafeteria/Kitchen - La Jolla High_13-17 Building Exterior, Southwest Corner of BLDG Left Side	DWO-342-035	Drinking Fountain Bubblers	5.36	FLTR	4.83
36	500 Classrooms/Cafeteria/Kitchen - La Jolla High_13-17 Building Exterior, Southwest Corner of BLDG Right Side	DWO-342-036	Drinking Fountain Bubblers	ND	INIT	
37	500 Classrooms/Cafeteria/Kitchen - La Jolla High_13-17 Corridor 1st Floor, South End of Hall West Wall Left Side	DWO-342-037	Drinking Fountain Bubblers	3.90	INIT	
38	500 Classrooms/Cafeteria/Kitchen - La Jolla High_13-17 Corridor 1st Floor, South End of Hall West Wall Right Side	DWO-342-038	Drinking Fountain Bubblers	3.70	INIT	
39	500 Classrooms/Cafeteria/Kitchen - La Jolla High_13-17 Corridor 1st Floor, North End of Hall West Wall Left Side	DWO-342-039	Drinking Fountain Bubblers	1.40	INIT	
40	500 Classrooms/Cafeteria/Kitchen - La Jolla High_13-17 Corridor 1st Floor, North End of Hall West Wall Right Side	DWO-342-040	Drinking Fountain Bubblers	3.30	INIT	
41	500 Classrooms/Cafeteria/Kitchen - La Jolla High_13-17 Corridor 2nd Floor, North End of Hall West Wall Left Side	DWO-342-041	Drinking Fountain Bubblers	3.30	INIT	
42	500 Classrooms/Cafeteria/Kitchen - La Jolla High_13-17 Corridor 2nd Floor, North End of Hall West Wall Right Side	DWO-342-042	Drinking Fountain Bubblers	2.30	INIT	
43	500 Classrooms/Cafeteria/Kitchen - La Jolla High_13-17 Corridor 2nd Floor, South End of Hall West Wall Left Side	DWO-342-043	Drinking Fountain Bubblers	8.20	FLTR	2.67
44	500 Classrooms/Cafeteria/Kitchen - La Jolla High_13-17 Corridor 2nd Floor, South End of Hall West Wall Right Side	DWO-342-044	Drinking Fountain Bubblers	8.30	FLTR	ND
45	600 Classrooms - La Jolla High_14-23 Classroom - 602C, West Wall	DWO-342-045	Drinking Fountain Bubblers	5.70	FLTR	4.35
46	600 Classrooms - La Jolla High_14-23 Auto Shop, South Wall	DWO-342-046	Drinking Fountain Bubblers	3.40	INIT	
47	600 Classrooms - La Jolla High_14-23 Classroom - 604 Graphic Arts, East Wall	DWO-342-047	Drinking Fountain Bubblers	6.40	FLTR	ND
48	900 Classrooms/Elevator - La Jolla High Building Exterior, Southeast Corner Left Side	DWO-342-048	Drinking Fountain Bubblers	<5	INIT	
49	900 Classrooms/Elevator - La Jolla High Building Exterior, Southeast Corner Right Side	DWO-342-049	Drinking Fountain Bubblers	0.59	INIT	
50	900 Classrooms/Elevator - La Jolla High Building Exterior, North Wall Left Side	DWO-342-050	Drinking Fountain Bubblers	0.70	INIT	
51	900 Classrooms/Elevator - La Jolla High Building Exterior, North Wall Right Side	DWO-342-051	Drinking Fountain Bubblers	1.30	INIT	



SAN DIEGO UNIFIED SCHOOL DISTRICT DRINKING WATER SAMPLING REPORT

Facility: La Jolla High School

Report Type: Close Out Report

Date of Report: 10/23/2018

	Location	DWO No	Type	Initial Result*	Action Taken**	Clearance Result
52	900 Classrooms/Elevator - La Jolla High Building Exterior, 2nd FL SE Corner Near Entrance to Rm	DWO-342-052	Drinking Fountain Bubblers	0.40	INIT	
53	900 Classrooms/Elevator - La Jolla High Building Exterior, 2nd FI SE Corner Near Entrance to Rm	DWO-342-053	Drinking Fountain Bubblers	0.29	INIT	
54	800 Classroom 803 - La Jolla High_14-24 Classroom - 803, North Wall	DWO-342-054	Drinking Fountain Bubblers	7.20	FLTR	ND
55	Concession/Restrooms - La Jolla High_19-30 Building Exterior, SE Corner of BLDG	DWO-342-055	Drinking Fountain Bubblers	0.23	INIT	
56	Concession/Restrooms - La Jolla High_19-30 Building Exterior, SE Corner of BLDG	DWO-342-056	Drinking Fountain Bubblers	0.26	INIT	
57	Concession West Visitor Side - La Jolla High_19-31 Building Exterior, South End of BLDG	DWO-342-057	Drinking Fountain Bubblers	0.14	INIT	
58	Concession West Visitor Side - La Jolla High_19-31 Building Exterior, South End of BLDG	DWO-342-058	Drinking Fountain Bubblers	0.21	INIT	
59	Equipment/Spin Rm - La Jolla High_19-34 Building Exterior, South End of BLDG	DWO-342-059	Drinking Fountain Bubblers	0.22	INIT	
60	Equipment/Spin Rm - La Jolla High_19-34 Building Exterior, South End of BLDG	DWO-342-060	Drinking Fountain Bubblers	0.17	INIT	
61	Equipment/Spin Rm - La Jolla High_19-34 Building Exterior, Near RR	DWO-342-061	Drinking Fountain Bubblers	0.08	INIT	
62	Equipment/Spin Rm - La Jolla High_19-34 Building Exterior, Near RR	DWO-342-062	Drinking Fountain Bubblers	0.13	INIT	
63	1000 Gym/Girls Locker Rm - La Jolla High_12-16 Gymnasium Big, EAST WALL	DWO-342-063	Drinking Fountain Bubblers	5.90	PLMB	ND
64	1000 Gym/Girls Locker Rm - La Jolla High_12-16 Wrestling Rm, West Wall	DWO-342-064	Drinking Fountain Bubblers	4.10	INIT	
65	1000 Gym/Girls Locker Rm - La Jolla High_12-16 Gymnasium Big, West Wall	DWO-342-065	Drinking Fountain Bubblers	1.70	INIT	
66	#N/A	DWO-342-066	#N/A	5.50	RMOV	NA
67	1000 Gym/Girls Locker Rm - La Jolla High_12-16 Building Exterior, North Wall Center of BLDG Left Side	DWO-342-067	Drinking Fountain Bubblers	1.60	INIT	



SAN DIEGO UNIFIED SCHOOL DISTRICT DRINKING WATER SAMPLING REPORT

Facility: La Jolla High School

Report Type: Close Out Report

Date of Report: 10/23/2018

Location	DWO No	Type	Initial Result*	Action Taken**	Clearance Result
68 1000 Gym/Girls Locker Rm - La Jolla High_12-16 Building Exterior, North Wall Center of BLDG Right Side	DWO-342-068	Drinking Fountain Bubbler	2.50	INIT	
69 1000 Gym/Girls Locker Rm - La Jolla High_12-16 Training Rm in Small Gym, South Wall	DWO-342-069	Faucet	3.80	INIT	
70 1000 Gym/Girls Locker Rm - La Jolla High_12-16 Gymnasium Small, East Wall	DWO-342-070	Drinking Fountain Bubbler	4.70	INIT	
71 1000 Gym/Girls Locker Rm - La Jolla High_12-16 Gymnasium Small, West Wall	DWO-342-071	Drinking Fountain Bubbler	2.00	INIT	
72 1000 Gym/Girls Locker Rm - La Jolla High_12-16 Building Exterior, North Wall Near RR	DWO-342-072	Drinking Fountain Bubbler	1.70	INIT	

*Action levels and color indication

Federal action level is above 15ppb (parts per billion). SDUSD uses an action level that is stricter and includes anything above 5 PPB. Items indicated in green are below District action level. Items indicated in yellow are above District action level. Items indicated in red are above both District and Federal action levels. Green indicates no action needed. Red/Yellow indicates action needed.

**Clearance actions

INIT=Initial result cleared no action needed. FLTR=Filter has been installed. PLMB=Plumbing work performed. RRC=Repeat and repeat-confirmation testing has been performed and both samples yielded results below District action level. RMOV=The drinking water outlet has been removed from service.