



March 15, 2018

Tammy Cannon
Principal
Montezuma CDC
4950 Curry Dr.
San Diego, CA 92115

Subject: Water quality at Montezuma CDC campus project closeout

Dear Tammy:

The following information is provided as a project closeout report for the recent whole-site drinking water quality investigation and remediation work at the Montezuma CDC campus.

On June 28, 2017 the district Safety Office sampled the water quality at Montezuma CDC as a proactive effort to identify water quality issues. The locations tested are listed on the attached list of sampled locations. The Safety Office staff collected water samples from the site and delivered the samples to an accredited local laboratory for analysis to detect the presence of lead in the drinking water. The federal EPA standard for lead in drinking water is 15 parts per billion (ppb) however; the District standard is much more stringent at 5 ppb.

The attached report shows that some drinking water fixtures required remedial action to address any fixtures greater than 5 ppb. Those drinking water fixtures that measured above the district standard have been identified and tagged "out of service". Once the remedial action was completed, a drinking water re-test was conducted and were cleared by the Safety Office (see attached list for details). All site repairs are complete and drinking water outlets now meet district standards. This project is considered closed with no further action from the District.

Sincerely,

A handwritten signature in black ink, appearing to read "Darin Vey".

Darin Vey
Manager (TOC); Safety, Training, Personnel, & Environmental Compliance

