

June 12, 2019

Ryan Woodard
Principal
Harriet Tubman Village School
6880 Mohawk Street
San Diego, CA 92115

Subject: Harriet Tubman Village Drinking Water Project Closeout

Dear Mr. Woodard:

The following information is provided as a project closeout report for the recent drinking water lead remediation work at the Harriet Tubman Village School campus.

As part of a Districtwide effort the Physical Plant Operations (PPO) staff began testing all drinking water outlets at Harriet Tubman Village for elevated levels of lead. PPO staff first identified all drinking water outlets and tagged them with a blue label. Safety Office staff then collected water samples from each drinking water outlet and delivered the samples to a state certified laboratory for analysis. The federal EPA standard for lead in drinking water is 15 parts per billion (ppb); however, the district standard is much more stringent at 5 ppb. Drinking water fixtures that measured above the district standard were tagged "out of service" while remedial actions took place.

The attached report shows that some drinking water fixtures required remedial action in order to meet the district's strict standard of 5 ppb. Once the remedial action was completed, a re-test was conducted to confirm the remedial action was successful. All site repairs are now complete, please see the attached sampling log for more information. This project is considered closed.

Now that all drinking water outlets on the Harriet Tubman Village campus meet the district's lead standard of 5 ppb, your campus is now cleared from the district's daily water flushing requirement. Instead, please instruct staff to flush all drinking water outlets marked with a blue sticker for one minute in the morning of the first day of school each week, rather than every morning. Please let me know if you have any questions.

Sincerely,

Steven J. Ditto
Manager, Facilities Planning



SAN DIEGO UNIFIED SCHOOL DISTRICT DRINKING WATER SAMPLING REPORT

Facility: Tubman Charter

Report Type: Closeout Report

Date of Report: 06/12/19

| | Location | DWO No | Type | Initial Result* | Action Taken** | Clearance Result |
|----|---|-------------|----------------------------|-----------------|----------------|------------------|
| 1 | 2 Admin/Classrooms - Harriet Tubman_02-02 Office Counselers, east wall | DWO-214-001 | Faucet | 4.49 | | |
| 2 | 2 Admin/Classrooms - Harriet Tubman_02-02 Nurse Office, west wall | DWO-214-002 | Drinking Fountain Bubblers | 1.87 | | |
| 3 | 2 Admin/Classrooms - Harriet Tubman_02-02 Classroom - 02, east wall | DWO-214-003 | Drinking Fountain Bubblers | 0.46 | | |
| 4 | 2 Admin/Classrooms - Harriet Tubman_02-02 Classroom - 05, west wall | DWO-214-004 | Drinking Fountain Bubblers | 0.71 | | |
| 5 | 2 Admin/Classrooms - Harriet Tubman_02-02 Classroom - 03, east wall | DWO-214-005 | Drinking Fountain Bubblers | 0.58 | | |
| 6 | 2 Admin/Classrooms - Harriet Tubman_02-02 Classroom - 04, west wall | DWO-214-006 | Drinking Fountain Bubblers | 0.94 | | |
| 7 | 3 Multi-Purpose/Kitchen - Harriet Tubman_03-03 Building Exterior, northeast wall left side | DWO-214-007 | Drinking Fountain Bubblers | 1.55 | | |
| 8 | 3 Multi-Purpose/Kitchen - Harriet Tubman_03-03 Building Exterior, northeast wall middle left | DWO-214-008 | Drinking Fountain Bubblers | 0.89 | | |
| 9 | 3 Multi-Purpose/Kitchen - Harriet Tubman_03-03 Building Exterior, northeast wall middle right | DWO-214-009 | Drinking Fountain Bubblers | 0.95 | | |
| 10 | 3 Multi-Purpose/Kitchen - Harriet Tubman_03-03 Building Exterior, northeast wall right side | DWO-214-010 | Drinking Fountain Bubblers | 1.02 | | |
| 11 | 3 Multi-Purpose/Kitchen - Harriet Tubman_03-03 Building Exterior, middle north wall left side | DWO-214-011 | Drinking Fountain Bubblers | 2.09 | | |
| 12 | 3 Multi-Purpose/Kitchen - Harriet Tubman_03-03 Building Exterior, middle north wall middle left | DWO-214-012 | Drinking Fountain Bubblers | 1.84 | | |
| 13 | 3 Multi-Purpose/Kitchen - Harriet Tubman_03-03 Building Exterior, middle north wall middle right | DWO-214-013 | Drinking Fountain Bubblers | <5 | | |
| 14 | 3 Multi-Purpose/Kitchen - Harriet Tubman_03-03 Building Exterior, middle north wall right side. | DWO-214-014 | Drinking Fountain Bubblers | 3.86 | | |
| 15 | 3 Multi-Purpose/Kitchen - Harriet Tubman_03-03 Multi-Purpose Rm, north wall | DWO-214-015 | Drinking Fountain Bubblers | 2.22 | | |
| 16 | 3 Multi-Purpose/Kitchen - Harriet Tubman_03-03 Kitchen, west wall | DWO-214-016 | Faucet | 9.84 | FLTR | 4.72 |



SAN DIEGO UNIFIED SCHOOL DISTRICT DRINKING WATER SAMPLING REPORT

Facility: Tubman Charter

Report Type: Closeout Report

Date of Report: 06/12/19

| | Location | DWO No | Type | Initial Result* | Action Taken** | Clearance Result |
|----|---|-------------|--------------------------|-----------------|----------------|------------------|
| 17 | 4 Kinder Rms 1-2 - Harriet Tubman_03-04 Classroom - KG1, east wall | DWO-214-017 | Drinking Fountain Bubler | 1.98 | | |
| 18 | 4 Kinder Rms 1-2 - Harriet Tubman_03-04 Classroom - KG1, east wall | DWO-214-018 | Drinking Fountain Bubler | <5 | | |
| 19 | 5 Library - Harriet Tubman_04-05 Restroom Faculty Uni-sex, South Wall | DWO-214-019 | Faucet | 0.39 | | |
| 20 | Portable B12 - Harriet Tubman Classroom - B12, west wall | DWO-214-020 | Drinking Fountain Bubler | 0.35 | | |
| 21 | Portable B11 - Harriet Tubman Classroom - B11, west wall | DWO-214-021 | Drinking Fountain Bubler | 0.35 | | |
| 22 | Portable B10 - Harriet Tubman Classroom - B10, west wall | DWO-214-022 | Drinking Fountain Bubler | 0.36 | | |
| 23 | Portable B09 - Harriet Tubman Classroom - B09, west wall | DWO-214-023 | Drinking Fountain Bubler | 0.59 | | |
| 24 | Portable B13 - Harriet Tubman Classroom - B13, east wall | DWO-214-024 | Drinking Fountain Bubler | 0.56 | | |
| 25 | Portable B14 - Harriet Tubman Classroom - B14, east wall | DWO-214-025 | Drinking Fountain Bubler | 0.32 | | |
| 26 | Portable B16 - Harriet Tubman Classroom - B16, west wall | DWO-214-026 | Drinking Fountain Bubler | 0.45 | | |
| 27 | Portable B17 - Harriet Tubman Classroom - B17, west wall | DWO-214-027 | Drinking Fountain Bubler | 0.42 | | |
| 28 | Portable B18 - Harriet Tubman Classroom - B18, west wall | DWO-214-028 | Drinking Fountain Bubler | 0.31 | | |
| 29 | Portable B15 - Harriet Tubman , west wall | DWO-214-029 | Drinking Fountain Bubler | 4.03 | | |
| 30 | Portable B08 - Harriet Tubman Classroom - B08, north wall | DWO-214-030 | Drinking Fountain Bubler | 2.08 | | |
| 31 | Portable B07 - Harriet Tubman Lounge, north wall | DWO-214-031 | Drinking Fountain Bubler | 11.02 | FLTR | ND |
| 32 | Portable B06 - Harriet Tubman Classroom - B06, north wall | DWO-214-032 | Drinking Fountain Bubler | 0.95 | | |



SAN DIEGO UNIFIED SCHOOL DISTRICT DRINKING WATER SAMPLING REPORT

Facility: Tubman Charter

Report Type: Closeout Report

Date of Report: 06/12/19

| | Location | DWO No | Type | Initial Result* | Action Taken** | Clearance Result |
|----|---|-------------|----------------------------|-----------------|----------------|------------------|
| 33 | 2 Admin/Classrooms - Harriet Tubman_02-02 Building Exterior, west wall left side | DWO-214-033 | Drinking Fountain Bubblers | 0.37 | | |
| 34 | 2 Admin/Classrooms - Harriet Tubman_02-02 Building Exterior, west wall middle | DWO-214-034 | Drinking Fountain Bubblers | <5 | | |
| 35 | 2 Admin/Classrooms - Harriet Tubman_02-02 Building Exterior, west wall right side | DWO-214-035 | Drinking Fountain Bubblers | 0.33 | | |
| 36 | 2 Admin/Classrooms - Harriet Tubman_02-02 Conference Rm, N wall | DWO-214-036 | Faucet | 1.14 | | |
| 37 | 4 Kinder Rms 1-2 - Harriet Tubman_03-04 Building Exterior, pedestal drinking fountain s side of bldg | DWO-214-037 | Drinking Fountain Bubblers | NA | | |
| 38 | 4 Kinder Rms 1-2 - Harriet Tubman_03-04 Building Exterior, pedestal drinking fountain s side of bldg | DWO-214-038 | Drinking Fountain Bubblers | NA | | |
| 39 | Portable Restrooms by B16 - Harriet Tubman Restroom Student Female, pedestal drinking fountain N | DWO-214-039 | Drinking Fountain Bubblers | ND | | |
| 40 | Portable Restrooms by B16 - Harriet Tubman Restroom Student Female, pedestal drinking fountain N | DWO-214-040 | Drinking Fountain Bubblers | <5 | | |
| 41 | Portable Restrooms by B06 - Harriet Tubman Building Exterior, S side of ramp, left bubbler | DWO-214-041 | Drinking Fountain Bubblers | 0.57 | | |
| 42 | Portable Restrooms by B06 - Harriet Tubman Building Exterior, S side of ramp, right bubbler | DWO-214-042 | Drinking Fountain Bubblers | 0.43 | | |

*Action levels and color indication

Federal action level is above 15 ppb (parts per billion). SDUSD uses an action level that is stricter and includes anything above 5 ppb. Items indicated in green are below District action level. Items indicated in yellow are above District action level. Items indicated in red are above both District and Federal action levels. Green indicates no action needed. Red/Yellow indicates action needed.

**Clearance actions

INIT=Initial result cleared no action needed. FLTR=Filter has been installed. PLMB=Plumbing work performed. RRC=Repeat and repeat-confirmation testing has been performed and both samples yielded results below District action level. RMOV=The drinking water outlet has been removed from service.