

SAN DIEGO UNIFIED SCHOOL DISTRICT DRINKING WATER SAMPLING

Site:	Wegeforth Elementary School	Report Date:	10/26/17	
Sampler:	SDUSD - Safety Office	Analyzed By:	EnvioMatrix Analytical, Inc	
<p>Federal Action Level (AL) is 15 parts per billion (PPB). District AL is 5 PPB. Green shading = below District & Federal Action Levels Yellow shading = below Federal Action level/Above District Action Level Red Shading = above Federal Action Level</p>				
Sample ID	Sample Location	Lead Results	Units	Type of Fixture
1	Main Building, Nurse's Office NW Side	2.96	ug/L	NS
2	Staff Lounge N-Wall Faucet	2.48	ug/L	KF
3	Outside Lunch Court, S-Wall, R-Side	2.40	ug/L	DB
4	Outside Lunch Court, S-Wall, L-Side	1.45	ug/L	DB
5	Outside Library, S-Wall, R-Side	2.28	ug/L	DB
6	Outside Library, S-Wall, L-Side	4.46	ug/L	DB
7	Library, inside small office-faucet	2.15	ug/L	KF
8	Room 1-SE corner	4.88	ug/L	DB
9	Room 2 - NE corner	5.26	ug/L	DB
10	Room 3 - SE corner SP-Ed	6.05	ug/L	DB
11	Room 4 - SW corner	2.50	ug/L	DB
12	Room 5 - NW corner	2.90	ug/L	DB
13	Room 6 - SW corner	3.06	ug/L	DB
14	Room 7, North East Wall, Bubbler - SP-Ed	5.24	ug/L	DB
15	Room 7, North East Wall, Faucet - SP-Ed	3.28	ug/L	CF
16	Room 8, South East Wall, Bubbler	2.44	ug/L	DB
17	Room 9 , North East Wall, Bubbler	5.63	ug/L	DB
18	Room 10, North West Wall, Bubbler	2.61	ug/L	DB
19	Room 11, South West Wall, Bubbler	8.82	ug/L	DB
20	North Wall Building 7-10, Triple Bubbler, Middle Bubbler	1.96	ug/L	DB
21	North Wall Building 7-10, Triple Bubbler, Far Left Bubbler	1.95	ug/L	DB
22	Office 03, North West Wall, Bubbler	3.33	ug/L	DB
23	Kindergarten Building -Room k-2 West Wall, L-Side	2.17	ug/L	DB
24	Kindergarten Building -Room k-2 West Wall, R-Side	3.09	ug/L	DB
25	Kindergarten Building - Room k-1 -Island	1.37	ug/L	DB
26	Bungalow-Room B2 - North Wall	0.88	ug/L	DB

Coding: DB=Drinking Water Bubbler; WC=Water Cooler; CF= Classroom Faucet; KF=Kitchen Faucet; NS=Nurse Faucet

