



Environmental Monitoring and Technical Services
2392 Kincaid Road MS 45A, San Diego, CA 92101
Tel(619) 758-2300 Fax (619) 758-2309

Water Quality Chemistry Services
Lead School Testing
Report Date: 5/5/17


San Diego Unified School District
Dingeman Elementary

Sample ID	Sample Date	Sample Time	Source	External ID	Lead	Units
W1168602	04/27/17	05:59 AM	SAMPLE 1	3710020-BCA-A	< 5	ug/L
W1168603	04/27/17	06:06 AM	SAMPLE 2	3710020-BCA-B	< 5	ug/L
W1168604	04/27/17	06:14 AM	SAMPLE 3	3710020-BCA-C	< 5	ug/L
W1168605	04/27/17	06:02 AM	SAMPLE 4	3710020-BCA-D	< 5	ug/L
W1168606	04/27/17	06:08 AM	SAMPLE 5	3710020-BCA-E	< 5	ug/L

Source **Source Description**

- SAMPLE 1 near Lunch Arbor, Between boys & girls RR and Custodian closet door, single bubbler right of triple bubbler fountain
- SAMPLE 2 B-4, NW end near RRs, triple bubbler fountain right of single bubbler fountain, right bubbler on triple fountain
- SAMPLE 3 Kinder playground behind kinder classrooms near street, single bubbler brinking fountain
- SAMPLE 4 B-20, inside classroom B-20 back of the room, bubbler at sink
- SAMPLE 5 B-16, inside classroom B-16 back of the room, bubbler at sink

DLR= State Mandated Detection Limit for Reporting (DLR)= 5 ug/L
Action Level (AL) = 15 ug/L


Doug Campbell, Senior Chemist