

Water Quality Chemistry Services  
 Lead School Testing  
 Report Date: 28-Apr-2017

San Diego Unified School District  
**Jefferson Elementary**

Sample ID	Sample Date	Sample Time	Source	External ID	Lead	Units
W1168027	4/21/2017	6:00 AM	SAMPLE 1	3710020-AIG-A	< 5	µg/L
W1168028	4/21/2017	6:04 AM	SAMPLE 2	3710020-AIG-B	< 5	µg/L
W1168029	4/21/2017	6:15 AM	SAMPLE 3	3710020-AIG-C	< 5	µg/L
W1168030	4/21/2017	6:07 AM	SAMPLE 4	3710020-AIG-D	< 5	µg/L
W1168031	4/21/2017	6:11 AM	SAMPLE 5	3710020-AIG-E	< 5	µg/L

**Source**      **Source Description**

- SAMPLE 1      Exterior fountain on free standing wall facing cafeteria, upper right bubbler.
- SAMPLE 2      Exterior wall mount, facing lunch court, between Girls/Boys RR, triple fountain, left bubbler
- SAMPLE 3      BLDG 200, 1st floor, between RM 202 and 203, double fountain, right bubbler
- SAMPLE 4      BLDG 800, 1st floor, between RMs 5 and 6, dual fountain, right bubbler
- SAMPLE 5      BLDG 800, 2nd floor, between RMs 13 and 14, dual fountain, left bubbler

DRL=State Mandated Detection Limit for Reporting (DLR)= 5 µg/L  
 Action Level (AL) = 15 µg/L



Doug Campbell, Senior Chemist