



Environmental Monitoring and Technical Services
2392 Kincaid Road MS 45A, San Diego, CA 92101
Tel(619) 758-2300 Fax (619) 758-2309

Water Quality Chemistry Services
Lead School Testing
Report Date: 5/26/17

San Diego Unified School District
Jonas Salk Elementary

Sample ID	Sample Date	Sample Time	Source	External ID	Lead	Units
W1172842	05/17/17	05:39 AM	SAMPLE 1	3710020-BID-A	< 5	ug/L
W1172843	05/17/17	05:42 AM	SAMPLE 2	3710020-BID-B	< 5	ug/L
W1172844	05/17/17	05:47 AM	SAMPLE 3	3710020-BID-C	< 5	ug/L
W1172845	05/17/17	05:50 AM	SAMPLE 4	3710020-BID-D	< 5	ug/L
W1172846	05/17/17	05:53 AM	SAMPLE 5	3710020-BID-E	< 5	ug/L

Source **Source Description**

- SAMPLE 1 Multi-Purpose Room, Wall mounted interior (East of the Room), facing stage, next to restroom, two single bubbler fountains, lower right fountain
- SAMPLE 2 Wall mounted exterior (Southwest of the Bldg), next to Gas Shut off, upper left fountain
- SAMPLE 3 400 bldg-Upstairs, inside room 400 (West of Bldg), bubbler at sink
- SAMPLE 4 500 bldg-Downstairs, Kindergarten room 503, bubbler at sink
- SAMPLE 5 700 bldg, room 700, classroom sink between ES Office & Classroom 701, bubbler at sink

DLR= State Mandated Detection Limit for Reporting (DLR)= 5 ug/L
Action Level (AL) = 15 ug/L


Doug Campbell, Senior Chemist