



Environmental Monitoring and Technical Services  
2392 Kincaid Road MS 45A, San Diego, CA 92101  
Tel(619) 758-2300 Fax (619) 758-2309

Water Quality Chemistry Services  
Lead School Testing  
Report Date: 5/12/17

San Diego Unified School District  
**Joyner Elementary**

Sample ID	Sample Date	Sample Time	Source	External ID	Lead	Units
W1168592	05/05/17	06:01 AM	SAMPLE 1	3710020-AJB-A	< 5	ug/L
W1168593	05/05/17	06:06 AM	SAMPLE 2	3710020-AJB-B	< 5	ug/L
W1168594	05/05/17	06:04 AM	SAMPLE 3	3710020-AJB-C	< 5	ug/L
W1168595	05/05/17	06:09 AM	SAMPLE 4	3710020-AJB-D	< 5	ug/L
W1168596	05/05/17	06:11 AM	SAMPLE 5	3710020-AJB-E	< 5	ug/L

**Source**      **Source Description**

- SAMPLE 1 Cafeteria, outside - Next to lunch court and women rr at checkered wall, two single-bubbler fountains, lower left fountain
- SAMPLE 2 700 bldg., Inside rm. 703 at sink, Bubbler drinking fountain located at sink
- SAMPLE 3 600 bldg., outside of womens RR, four single bubbler fountains, far left top fountain
- SAMPLE 4 300 bldg., inside room 315 at sink, bubbler at sink
- SAMPLE 5 400 bldg., outside near room 402, two single bubbler fountains, lower left fountain

DLR= State Mandated Detection Limit for Reporting (DLR)= 5 ug/L  
Action Level (AL) = 15 ug/L

  
Doug Campbell, Senior Chemist