



Environmental Monitoring and Technical Services
2392 Kincaid Road MS 45A, San Diego, CA 92101
Tel(619) 758-2300 Fax (619) 758-2309

Water Quality Chemistry Services
Lead School Testing
Report Date: 5/12/17

San Diego Unified School District
Language Academy

Sample ID	Sample Date	Sample Time	Source	External ID	Lead	Units
W1171125	05/05/17	06:09 AM	SAMPLE 1	3710020-AJF-A	5.58	ug/L
W1171126	05/05/17	05:53 AM	SAMPLE 2	3710020-AJF-B	< 5	ug/L
W1171127	05/05/17	06:04 AM	SAMPLE 3	3710020-AJF-C	6.61	ug/L
W1171128	05/05/17	05:58 AM	SAMPLE 4	3710020-AJF-D	< 5	ug/L
W1171129	05/05/17	06:01 AM	SAMPLE 5	3710020-AJF-E	6.13	ug/L

Source **Source Description**

- SAMPLE 1 100 Bldg.; NE corner of building (outside room 11); Left-side bubbler on a 2-bubbler fountain
- SAMPLE 2 400 Building; Exterior N side of Bldg.; Middle bubbler of 3 separate single fountains
- SAMPLE 3 400 Bldg.; Rm 4; Interior 2-compartment sink; single bubbler on R side of sink
- SAMPLE 4 400 Building; SW corner of building outside of room 3; Upper L bubbler of 2 separate single fountains
- SAMPLE 5 Kindergarten building; Inside RM 2; Single bubbler on R side of a single sink

DLR= State Mandated Detection Limit for Reporting (DLR)= 5 ug/L
Action Level (AL) = 15 ug/L


Doug Campbell, Senior Chemist