



# SAN DIEGO UNIFIED SCHOOL DISTRICT DRINKING WATER SAMPLING REPORT

Facility: Miller ES

Report Type: Progress Report

Date of Report: 03/11/19

	Location	DWO No	Type	Initial Result*	Action Taken**	Clearance Result
1	200 Admin - Miller_02-06 Nurse Health, S Wall, By Restrooms	DWO-206-008	Faucet	5.37		
2	200 Admin - Miller_02-06 Workroom, N Wall	DWO-206-009	Faucet	2.02		
3	300 Classrooms 30-35 - Miller_01-04 Classroom - 31, N Wall	DWO-206-010	Drinking Fountain Bubblers	0.31		
4	300 Classrooms 30-35 - Miller_01-04 Classroom - 33, N Wall	DWO-206-011	Drinking Fountain Bubblers	0.61		
5	300 Classrooms 30-35 - Miller_01-04 Classroom - 35, N Wall	DWO-206-012	Drinking Fountain Bubblers	0.40		
6	300 Classrooms 30-35 - Miller_01-04 Corridor, Sw End Of Hall, Left Fixture	DWO-206-013	Drinking Fountain Bubblers	0.42		
7	300 Classrooms 30-35 - Miller_01-04 Corridor, Sw End Of Hall, Right Fixture	DWO-206-014	Drinking Fountain Bubblers	0.37		
8	300 Classrooms 30-35 - Miller_01-04 Classroom - 34, S Wall	DWO-206-015	Drinking Fountain Bubblers	0.41		
9	300 Classrooms 30-35 - Miller_01-04 Classroom - 32, S Wall	DWO-206-016	Drinking Fountain Bubblers	0.32		
10	300 Classrooms 30-35 - Miller_01-04 Classroom - 30, S Wall	DWO-206-017	Drinking Fountain Bubblers	0.27		
11	400 Classrooms 40-47 - Miller_01-03 Classroom - 41, W Wall	DWO-206-018	Drinking Fountain Bubblers	0.31		
12	400 Classrooms 40-47 - Miller_01-03 Classroom - 43, W Wall	DWO-206-019	Drinking Fountain Bubblers	0.39		
13	400 Classrooms 40-47 - Miller_01-03 Classroom - 43, W Wall	DWO-206-020	Drinking Fountain Bubblers	0.44		
14	400 Classrooms 40-47 - Miller_01-03 Classroom - 47, W Wall	DWO-206-021	Drinking Fountain Bubblers	0.37		
15	400 Classrooms 40-47 - Miller_01-03 Classroom - 46, E Wall	DWO-206-024	Drinking Fountain Bubblers	0.66		
16	400 Classrooms 40-47 - Miller_01-03 Classroom - 44, E Wall	DWO-206-025	Drinking Fountain Bubblers	0.43		



# SAN DIEGO UNIFIED SCHOOL DISTRICT DRINKING WATER SAMPLING REPORT

Facility: Miller ES

Report Type: Progress Report

Date of Report: 03/11/19

	Location	DWO No	Type	Initial Result*	Action Taken**	Clearance Result
17	400 Classrooms 40-47 - Miller_01-03 Classroom - 42, E Wall	DWO-206-026	Drinking Fountain Bubblers	0.40		
18	400 Classrooms 40-47 - Miller_01-03 Classroom - 40, E Wall	DWO-206-027	Drinking Fountain Bubblers	0.50		
19	500 Classrooms 50-57 - Miller_01-02 Corridor, Nw End Of Corridor, Left Fixture	DWO-206-028	Drinking Fountain Bubblers	0.23		
20	500 Classrooms 50-57 - Miller_01-02 Corridor, Nw End Of Corridor, Right Fixture	DWO-206-029	Drinking Fountain Bubblers	0.36		
21	500 Classrooms 50-57 - Miller_01-02 Classroom - 51, W Wall	DWO-206-030	Drinking Fountain Bubblers	0.20		
22	500 Classrooms 50-57 - Miller_01-02 Classroom - 53, W Wall	DWO-206-031	Drinking Fountain Bubblers	0.31		
23	500 Classrooms 50-57 - Miller_01-02 Classroom - 55, W Wall	DWO-206-032	Drinking Fountain Bubblers	0.26		
24	500 Classrooms 50-57 - Miller_01-02 Classroom - 57, W Wall	DWO-206-033	Drinking Fountain Bubblers	0.29		
25	500 Classrooms 50-57 - Miller_01-02 Classroom - 56, E Wall	DWO-206-034	Drinking Fountain Bubblers	0.33		
26	500 Classrooms 50-57 - Miller_01-02 Classroom - 54, E Wall	DWO-206-035	Drinking Fountain Bubblers	0.32		
27	500 Classrooms 50-57 - Miller_01-02 Classroom - 52, E Wall	DWO-206-036	Drinking Fountain Bubblers	0.37		
28	500 Classrooms 50-57 - Miller_01-02 Classroom - 50, E Wall	DWO-206-037	Drinking Fountain Bubblers	0.35		
29	600 Classrooms 60-67 - Miller_01-01 Classroom - 61, S Wall	DWO-206-038	Drinking Fountain Bubblers	0.36		
30	600 Classrooms 60-67 - Miller_01-01 Classroom - 63, S Wall	DWO-206-039	Drinking Fountain Bubblers	0.42		
31	600 Classrooms 60-67 - Miller_01-01 Classroom - 65, S Wall	DWO-206-040	Drinking Fountain Bubblers	0.30		
32	600 Classrooms 60-67 - Miller_01-01 Classroom - 67, S Wall	DWO-206-041	Drinking Fountain Bubblers	0.35		



# SAN DIEGO UNIFIED SCHOOL DISTRICT DRINKING WATER SAMPLING REPORT

Facility: Miller ES

Report Type: Progress Report

Date of Report: 03/11/19

	Location	DWO No	Type	Initial Result*	Action Taken**	Clearance Result
33	600 Classrooms 60-67 - Miller_01-01 Corridor, Ne End Of Corridor, Left Fixture	DWO-206-042	Drinking Fountain Bubblers	0.33		
34	600 Classrooms 60-67 - Miller_01-01 Corridor, Ne End Of Corridor, Right Fixture	DWO-206-043	Drinking Fountain Bubblers	0.47		
35	600 Classrooms 60-67 - Miller_01-01 Classroom - 66, N Wall	DWO-206-044	Drinking Fountain Bubblers	0.34		
36	600 Classrooms 60-67 - Miller_01-01 Classroom - 64, N Wall	DWO-206-045	Drinking Fountain Bubblers	0.34		
37	600 Classrooms 60-67 - Miller_01-01 Classroom - 62, N Wall	DWO-206-046	Drinking Fountain Bubblers	0.36		
38	600 Classrooms 60-67 - Miller_01-01 Classroom - 60, N Wall	DWO-206-047	Drinking Fountain Bubblers	0.30		
39	700 Classrooms 70-79 - Miller_03-07 Classroom - 79, S Wall	DWO-206-048	Drinking Fountain Bubblers	0.36		
40	700 Classrooms 70-79 - Miller_03-07 Classroom - 78, E Wall	DWO-206-049	Drinking Fountain Bubblers	0.17		
41	700 Classrooms 70-79 - Miller_03-07 Classroom - 77, S Wall	DWO-206-050	Drinking Fountain Bubblers	0.33		
42	700 Classrooms 70-79 - Miller_03-07 Classroom - 76, S Wall	DWO-206-051	Drinking Fountain Bubblers	0.44		
43	700 Classrooms 70-79 - Miller_03-07 Classroom - 75, W Wall	DWO-206-052	Drinking Fountain Bubblers	0.30		
44	700 Classrooms 70-79 - Miller_03-07 Classroom - 74, S Wall	DWO-206-053	Drinking Fountain Bubblers	ND		
45	700 Classrooms 70-79 - Miller_03-07 Music Rm, N Wall	DWO-206-054	Drinking Fountain Bubblers	0.32		
46	700 Classrooms 70-79 - Miller_03-07 Music Rm, N Wall	DWO-206-055	Drinking Fountain Bubblers	0.39		
47	700 Classrooms 70-79 - Miller_03-07 Hallway, N Wall, Left Fixture	DWO-206-056	Drinking Fountain Bubblers	0.23		
48	700 Classrooms 70-79 - Miller_03-07 Hallway, N Wall Right Fixture	DWO-206-057	Drinking Fountain Bubblers	0.23		



# SAN DIEGO UNIFIED SCHOOL DISTRICT DRINKING WATER SAMPLING REPORT

Facility: Miller ES

Report Type: Progress Report

Date of Report: 03/11/19

	Location	DWO No	Type	Initial Result*	Action Taken**	Clearance Result
49	700 Classrooms 70-79 - Miller_03-07 Music Rm, N Wall	DWO-206-058	Drinking Fountain Bubblers	0.22		
50	700 Classrooms 70-79 - Miller_03-07 Classroom - 70, N Wall	DWO-206-059	Drinking Fountain Bubblers	0.19		
51	100 Auditorium/Kitchen/Media Center/Supply - Miller_02-05	DWO-206-060	Drinking Fountain Bubblers	2.44		
52	100 Auditorium/Kitchen/Media Center/Supply - Miller_02-05	DWO-206-061	Drinking Fountain Bubblers	3.17		
53	100 Auditorium/Kitchen/Media Center/Supply - Miller_02-05	DWO-206-062	Faucet	1.25		
54	100 Auditorium/Kitchen/Media Center/Supply - Miller_02-05	DWO-206-063	Spray Faucet	0.90		

\*Action levels and color indication

Federal action level is above 15ppb (parts per billion). SDUSD uses an action level that is stricter and includes anything above 5 PPB. Items indicated in green are below District action level. Items indicated in yellow are above District action level. Items indicated in red are above both District and Federal action levels. Green indicates no action needed. Red/Yellow indicates action needed.

\*\*Clearance actions

INIT=Initial result cleared no action needed. FLTR=Filter has been installed. PLMB=Plumbing work performed. RRC=Repeat and repeat-confirmation testing has been performed and both samples yielded results below District action level. RMOV=The drinking water outlet has been removed from service.