



SAN DIEGO UNIFIED SCHOOL DISTRICT DRINKING WATER SAMPLING REPORT

Facility: Ocean Beach ES

Report Type: Progress Report

Date of Report: 12/14/2018

	Location	DWO No	Type	Initial Result*	Action Taken**	Clearance Result
1	Admin/Aud/Cafe/Kitchen/Rms 1-14 - Ocean Beach Nurse Health, West Wall	DWO-225-001	Faucet	2.68		
2	Admin/Aud/Cafe/Kitchen/Rms 1-14 - Ocean Beach Workroom by Rm 14, North Wall	DWO-225-002	Faucet	4.48		
3	Classrooms 15-19/Supply - Ocean Beach Classroom - 15, South Wall	DWO-225-003	Drinking Fountain Bubblers	ND		
4	Classrooms 15-19/Supply - Ocean Beach Classroom - 16, East Wall	DWO-225-004	Drinking Fountain Bubblers	ND		
5	Classrooms 15-19/Supply - Ocean Beach Classroom - 19, East Wall	DWO-225-005	Drinking Fountain Bubblers	ND		
6	Classrooms 15-19/Supply - Ocean Beach Building Exterior, East Wall	DWO-225-006	Drinking Fountain Bubblers	2.51		
7	Classrooms 15-19/Supply - Ocean Beach Building Exterior, East Wall	DWO-225-007	Drinking Fountain Bubblers	ND		
8	Classrooms 20-21 - Ocean Beach_10-11 Classroom - 20, West Wall	DWO-225-008	Drinking Fountain Bubblers	ND		
9	Classrooms 20-21 - Ocean Beach_10-11 Classroom - 20, West Wall	DWO-225-009	Drinking Fountain Bubblers	5.13	FLTR	ND
10	Classrooms 20-21 - Ocean Beach_10-11 Classroom - 21, East Wall	DWO-225-010	Drinking Fountain Bubblers	ND		
11	Portable B06 - Ocean Beach Classroom - B06, East Wall	DWO-225-011	Drinking Fountain Bubblers	ND		
12	Portable B05 - Ocean Beach Classroom - B05, East Wall	DWO-225-012	Drinking Fountain Bubblers	ND		
13	Portable B04 - Ocean Beach Classroom - B04, South Wall	DWO-225-013	Drinking Fountain Bubblers	ND		
14	Portable B03 - Ocean Beach Classroom - B03, South Wall	DWO-225-014	Drinking Fountain Bubblers	ND		
15	Classrooms 9-12 - Ocean Beach_11-12 Classroom - 09, North Wall	DWO-225-015	Drinking Fountain Bubblers	ND		
16	Classrooms 9-12 - Ocean Beach_11-12 Classroom - 11, South Wall	DWO-225-016	Drinking Fountain Bubblers	Under Repair		
17	Classrooms 9-12 - Ocean Beach_11-12 Classroom - 12, South Wall	DWO-225-017	Drinking Fountain Bubblers	ND		



SAN DIEGO UNIFIED SCHOOL DISTRICT DRINKING WATER SAMPLING REPORT

Facility: Ocean Beach ES

Report Type: Progress Report

Date of Report: 12/14/2018

	Location	DWO No	Type	Initial Result*	Action Taken**	Clearance Result
18	Classrooms 9-12 - Ocean Beach_11-12 Classroom - 10, North Wall	DWO-225-018	Drinking Fountain Bubler	ND		
19	Library - Ocean Beach_12-14 Workroom, South Wall	DWO-225-019	Faucet	ND		
20	Lunch Court Shelter - Ocean Beach Building Exterior, West Wall	DWO-225-020	Drinking Fountain Bubler	ND		
21	Lunch Court Shelter - Ocean Beach Building Exterior, West Wall	DWO-225-021	Drinking Fountain Bubler	ND		
22	Admin/Aud/Cafe/Kitchen/Rms 1-14 - Ocean Beach Classroom - 08, South Wall	DWO-225-022	Drinking Fountain Bubler	5.32		
23	Admin/Aud/Cafe/Kitchen/Rms 1-14 - Ocean Beach Classroom - 07, South Wall	DWO-225-023	Drinking Fountain Bubler	2.68		
24	Admin/Aud/Cafe/Kitchen/Rms 1-14 - Ocean Beach Kitchen, North Wall	DWO-225-024	Faucet	<5		
25	Admin/Aud/Cafe/Kitchen/Rms 1-14 - Ocean Beach Classroom - 03, West Wall	DWO-225-025	Drinking Fountain Bubler	4.70		
26	Admin/Aud/Cafe/Kitchen/Rms 1-14 - Ocean Beach Classroom - 03, West Wall	DWO-225-026	Drinking Fountain Bubler	2.77		
27	Admin/Aud/Cafe/Kitchen/Rms 1-14 - Ocean Beach Workroom, North Wall	DWO-225-027	Faucet	3.09		
28	Admin/Aud/Cafe/Kitchen/Rms 1-14 - Ocean Beach Workroom, West Wall	DWO-225-028	Faucet	8.01		
29	Admin/Aud/Cafe/Kitchen/Rms 1-14 - Ocean Beach Workroom by Rm 2, East Wall	DWO-225-029	Faucet	ND		
30	Admin/Aud/Cafe/Kitchen/Rms 1-14 - Ocean Beach Foyer by RR's, East Wall	DWO-225-030	Drinking Fountain Bubler	4.40		
31	Admin/Aud/Cafe/Kitchen/Rms 1-14 - Ocean Beach Foyer by RR's, East Wall	DWO-225-031	Drinking Fountain Bubler	4.45		
32	Admin/Aud/Cafe/Kitchen/Rms 1-14 - Ocean Beach Building Exterior, East Wall	DWO-225-032	Drinking Fountain Bubler	<5		
33	Admin/Aud/Cafe/Kitchen/Rms 1-14 - Ocean Beach Building Exterior, East Wall	DWO-225-033	Drinking Fountain Bubler	3.37		
34	Admin/Aud/Cafe/Kitchen/Rms 1-14 - Ocean Beach Classroom - 04, East Wall	DWO-225-034	Drinking Fountain Bubler	3.59		



SAN DIEGO UNIFIED SCHOOL DISTRICT DRINKING WATER SAMPLING REPORT

Facility: Ocean Beach ES

Report Type: Progress Report

Date of Report: 12/14/2018

Location	DWO No	Type	Initial Result*	Action Taken**	Clearance Result
35 Admin/Aud/Cafe/Kitchen/Rms 1-14 - Ocean Beach Classroom - 05, East Wall	DWO-225-035	Drinking Fountain Bubbler	7.02		
36 Admin/Aud/Cafe/Kitchen/Rms 1-14 - Ocean Beach Classroom - 06, East Wall	DWO-225-036	Drinking Fountain Bubbler	ND		
37 Kinder Rms K01-K02 - Ocean Beach_11-13 Building Exterior, South Wall	DWO-225-037	Drinking Fountain Bubbler	<5		
38 Kinder Rms K01-K02 - Ocean Beach_11-13 Building Exterior, South Wall	DWO-225-038	Drinking Fountain Bubbler	5.27		
39 Classrooms 15-19/Supply - Ocean Beach Building Exterior, West Wall Left	DWO-225-039	Drinking Fountain Bubbler	ND		
40 Classrooms 15-19/Supply - Ocean Beach Building Exterior, West Wall Right	DWO-225-040	Drinking Fountain Bubbler	ND		
41 Admin/Aud/Cafe/Kitchen/Rms 1-14 - Ocean Beach Workroom, North Wall	DWO-225-041	Faucet	ND		

*Action levels and color indication

Federal action level is above 15ppb (parts per billion). SDUSD uses an action level that is stricter and includes anything above 5 PPB. Items indicated in green are below District action level. Items indicated in yellow are above District action level. Items indicated in red are above both District and Federal action levels. Green indicates no action needed. Red/Yellow indicates action needed.

**Clearance actions

INIT=Initial result cleared no action needed. FLTR=Filter has been installed. PLMB=Plumbing work performed. RRC=Repeat and repeat-confirmation testing has been performed and both samples yielded results below District action level. RMOV=The drinking water outlet has been removed from service.