



Environmental Monitoring and Technical Services
2392 Kincaid Road MS 45A, San Diego, CA 92101
Tel(619) 758-2300 Fax (619) 758-2309

Water Quality Chemistry Services
Lead School Testing
Report Date: 5/23/17

San Diego Unified School District
Lindbergh/Schweitzer Elementary West

Sample ID	Sample Date	Sample Time	Source	External ID	Lead	Units
W1171845	05/13/17	06:57 AM	SAMPLE 1	3710020-BHB-A	< 5	ug/L
W1171846	05/13/17	07:01 AM	SAMPLE 2	3710020-BHB-B	< 5	ug/L
W1171847	05/13/17	07:03 AM	SAMPLE 3	3710020-BHB-C	< 5	ug/L
W1171848	05/13/17	07:06 AM	SAMPLE 4	3710020-BHB-D	< 5	ug/L
W1171849	05/13/17	07:10 AM	SAMPLE 5	3710020-BHB-E	< 5	ug/L

Source **Source Description**

- SAMPLE 1 Kitchen, West interior wall, spray nozzle above 2 compartment sink
- SAMPLE 2 Cafeteria/Auditorium, East exterior wall between cafeteria door & assembly door, two single bubbler fountains, right fountain
- SAMPLE 3 Classrooms 4-9 bldg, West exterior wall between boys and girls RR, three single bubbler fountains, center fountain
- SAMPLE 4 Classrooms 10-14 bldg, North exterior wall between boys and girls RR, dual bubbler fountain, right bubbler
- SAMPLE 5 South exterior wall between K-1 & K-2, two single bubbler sink/fountain combos, bubbler on right sink

DLR= State Mandated Detection Limit for Reporting (DLR)= 5 ug/L
Action Level (AL) = 15 ug/L


Doug Campbell, Senior Chemist