



Environmental Monitoring and Technical Services
2392 Kincaid Road MS 45A, San Diego, CA 92101
Tel(619) 758-2300 Fax (619) 758-2309


Water Quality Chemistry Services
Lead School Testing
Report Date: 4/28/17

San Diego Unified School District
Mckinley Elementary

Sample ID	Sample Date	Sample Time	Source	External ID	Lead	Units
W1167320	04/19/17	06:05 AM	SAMPLE 1	3710020-AGC-A	9.75	ug/L
W1167321	04/19/17	06:07 AM	SAMPLE 2	3710020-AGC-B	5.92	ug/L
W1167322	04/19/17	06:11 AM	SAMPLE 3	3710020-AGC-C	12.9	ug/L
W1167323	04/19/17	06:20 AM	SAMPLE 4	3710020-AGC-D	< 5	ug/L
W1167324	04/19/17	06:15 AM	SAMPLE 5	3710020-AGC-E	< 5	ug/L

<u>Source</u>	<u>Source Description</u>
SAMPLE 1	Media Center Building (Room #4), Bubbler at sink
SAMPLE 2	Outside Media Center Building (Room #4), one dual bubbler fountain, right bubbler
SAMPLE 3	Outside behind the Media Center at bottom of stairs, blue single bubbler fountain to the left of double bubbler fountain
SAMPLE 4	Outside Rooms 9 and 10 near RR, two single bubbler fountains, upper right fountain
SAMPLE 5	Outside RR's between B21 and B22, two single bubbler fountains, upper right fountain

DLR= State Mandated Detection Limit for Reporting (DLR)= 5 ug/L
Action Level (AL) = 15 ug/L


Tom Burger, Associate Chemist