



Environmental Monitoring and Technical Services  
2392 Kincaid Road MS 45A. San Diego, CA 92101  
Tel(619) 758-2300 Fax (619) 758-2309

Water Quality Chemistry Services  
Lead School Testing  
Report Date: 5/26/17

San Diego Unified School District  
**Pacific Beach Elementary**

Sample ID	Sample Date	Sample Time	Source	External ID	Lead	Units
W1170248	05/17/17	06:45 AM	SAMPLE 1	3710020-BFG-A	< 5	ug/L
W1170249	05/17/17	06:42 AM	SAMPLE 2	3710020-BFG-B	< 5	ug/L
W1170250	05/17/17	06:38 AM	SAMPLE 3	3710020-BFG-C	< 5	ug/L
W1170251	05/17/17	06:35 AM	SAMPLE 4	3710020-BFG-D	< 5	ug/L
W1170252	05/17/17	06:30 AM	SAMPLE 5	3710020-BFG-E	< 5	ug/L

**Source**      **Source Description**

- SAMPLE 1      Kinder Playground, Outside at wall between classrooms K1 & K2, dual fountain, right bubbler
- SAMPLE 2      Kindergarten, Inside K-2 at west wall, single bubbler fountain
- SAMPLE 3      building with rooms 6,8,& Boys RR, Outside wall near room 6, triple bubbler fountain, left bubbler
- SAMPLE 4      Inside room 12 at the sink near the corner by the window, bubbler at sink
- SAMPLE 5      Cafeteria / Auditorium Hall, Inside hallway west end next to cafeteria entrance door, two single-bubbler fountains, lower left fountain

DLR= State Mandated Detection Limit for Reporting (DLR)= 5 ug/L  
Action Level (AL) = 15 ug/L

  
Doug Campbell, Senior Chemist