



Environmental Monitoring and Technical Services
2392 Kincaid Road MS 45A, San Diego, CA 92101
Tel(619) 758-2300 Fax (619) 758-2309

Water Quality Chemistry Services
Lead School Testing
Report Date: 5/23/17


San Diego Unified School District
Twain Mesa Satellite

Sample ID	Sample Date	Sample Time	Source	External ID	Lead	Units
W1171694	05/10/17	06:33 AM	SAMPLE 1	3710020-BHG-A	< 5	ug/L

Source **Source Description**

SAMPLE 1 Portable Classrooms B5-B3, Wall mounted exterior (South of Bldg), between RRs, two single bubbler fountains, upper right fountain

DLR= State Mandated Detection Limit for Reporting (DLR)= 5 ug/L
Action Level (AL) = 15 ug/L


Doug Campbell, Senior Chemist