



Environmental Monitoring and Technical Services  
2392 Kincaid Road MS 45A, San Diego, CA 92101  
Tel(619) 758-2300 Fax (619) 758-2309

Water Quality Chemistry Services  
Lead School Testing  
Report Date: 4/12/17

San Diego Unified School District  
**Webster Elementary**

Sample ID	Sample Date	Sample Time	Description	External ID	Lead	Units
W1164507	04/06/17	06:15 AM	SAMPLE 1	3710020-ABI-A	< 5	ug/L
W1164508	04/06/17	06:00 AM	SAMPLE 2	3710020-ABI-B	7.14	ug/L
W1164509	04/06/17	06:02 AM	SAMPLE 3	3710020-ABI-C	< 5	ug/L
W1164510	04/06/17	06:05 AM	SAMPLE 4	3710020-ABI-D	5.09	ug/L
W1164511	04/06/17	06:10 AM	SAMPLE 5	3710020-ABI-E	< 5	ug/L

- SAMPLE 1 Main office, admin, nurses office,goosneck faucet (289-01)
- SAMPLE 2 Cafeteria, east facing wall, center bubbler (289-02)
- SAMPLE 3 BLDG rooms 6-9, west wall between boys/girls restroom, far right bubbler (289-03)
- SAMPLE 4 Bungalows, east facing, two triple fountains, left triple, far left bubbler (289-04)
- SAMPLE 5 Library, west facing, drinking fountains, right bubbler

DLR= State Mandated Detection Limit for Reporting (C)  
Action Level (AL) = 15 ug/L

  
Doug Campbell, Senior Chemist